



Certified
Environmental
Services, Inc.

7280 Caswell Street
North Syracuse, NY 13212
Phone 315-478-2374
Fax 315-478-2107

REPORT OF ANALYSES

Town Of Chenango
1529 NY Route 12
Binghamton, NY 13905-
Attn: Greg Burden

PROJECT NAME: Monthly Coliforms
DATE: 02/06/2026

SAMPLE NUMBER- 968225 SAMPLE ID- 1/Pennview WWTP
DATE SAMPLED- 02/04/26
DATE RECEIVED- 02/04/26 SAMPLER- Client
TIME RECEIVED- 1315 DELIVERED BY- Jack Plewak


SAMPLE MATRIX- WA
TIME SAMPLED- 0719
RECEIVED BY- EM
TYPE SAMPLE- Grab

Page 1 of 1

ANALYSIS	METHOD	ANALYSIS DATE	TIME	BY	RESULT UNITS
Sample Receipt Temperature		02/04/26		CES	1.4 Degrees C
Total Coliform	Colilert	02/04/26	1604	BLO	< 1 cfu/100ml

NYSDOH LAB ID NO. 11246

APPROVED BY:


(Terms and Conditions on Reverse Side)

Barbara L. DuChene
Laboratory Manager

Note: Reported result is negative.

The state sanitary code states that acceptable drinking water must contain no coliform bacteria. In order to be acceptable your sample must be "< 1". If your result is not "< 1" then you should call your local health department for advice on how to improve your water's quality. This sample meets NYS Standards for Total Coliform.

E-Coli Not Present

A copy of this report was sent
to the NYS Health Dept.



**Certified
Environmental
Services, Inc.**

7280 Caswell Street
North Syracuse, NY 13212
Phone 315-478-2374
Fax 315-478-2107

REPORT OF ANALYSES

Town Of Chenango
1529 NY Route 12
Binghamton, NY 13905-
Attn: Greg Burden

PROJECT NAME: Monthly Coliforms
DATE: 02/06/2026

SAMPLE NUMBER- 968226 SAMPLE ID- 2/Nirchis 957 Front St.
DATE SAMPLED- 02/04/26
DATE RECEIVED- 02/04/26 SAMPLER- Client
TIME RECEIVED- 1315 DELIVERED BY- Jack Plewak

SAMPLE MATRIX- WA
TIME SAMPLED- 0730
RECEIVED BY- EM
TYPE SAMPLE- Grab

Page 1 of 1

ANALYSIS	METHOD	ANALYSIS DATE	TIME	BY	RESULT UNITS
Sample Receipt Temperature		02/04/26		CES	1.4 Degrees C
Total Coliform	Colilert	02/04/26	1604	BLO	< 1 cfu/100ml

NYSDOH LAB ID NO. 11246

APPROVED BY:

(Terms and Conditions on Reverse Side)

Barbara L. DuChene
Laboratory Manager

Note: Reported result is negative.

The state sanitary code states that acceptable drinking water must contain no coliform bacteria. In order to be acceptable your sample must be "< 1". If your result is not "< 1" then you should call your local health department for advice on how to improve your water's quality. This sample meets NYS Standards for Total Coliform.

E-Coli Not Present

**A copy of this report was sent
to the NYS Health Dept.**



**Certified
Environmental
Services, Inc.**

7280 Caswell Street
North Syracuse, NY 13212
Phone 315-478-2374
Fax 315-478-2107

REPORT OF ANALYSES

Town Of Chenango
1529 NY Route 12
Binghamton, NY 13905-
Attn: Greg Burden

PROJECT NAME: Monthly Coliforms
DATE: 02/06/2026

SAMPLE NUMBER- 968227 SAMPLE ID- 3/1290 Front St.
DATE SAMPLED- 02/04/26
DATE RECEIVED- 02/04/26 SAMPLER- Client
TIME RECEIVED- 1315 DELIVERED BY- Jack Plewak

SAMPLE MATRIX- WA
TIME SAMPLED- 0757
RECEIVED BY- EM
TYPE SAMPLE- Grab

Page 1 of 1

ANALYSIS	METHOD	ANALYSIS DATE	TIME	BY	RESULT UNITS
Sample Receipt Temperature		02/04/26		CES	1.4 Degrees C
Total Coliform	Colilert	02/04/26	1604	BLO	< 1 cfu/100ml

NYSDOH LAB ID NO. 11246

APPROVED BY:

(Terms and Conditions on Reverse Side)

Barbara L. DuChene
Laboratory Manager

Note: Reported result is negative.

The state sanitary code states that acceptable drinking water must contain no coliform bacteria. In order to be acceptable your sample must be "< 1". If your result is not "< 1" then you should call your local health department for advice on how to improve your water's quality. This sample meets NYS Standards for Total Coliform.

E-Coli Not Present

**A copy of this report was sent
to the NYS Health Dept.**



**Certified
Environmental
Services, Inc.**

7280 Caswell Street
North Syracuse, NY 13212
Phone 315-478-2374
Fax 315-478-2107

REPORT OF ANALYSES

Town Of Chenango
1529 NY Route 12
Binghamton, NY 13905-
Attn: Greg Burden

PROJECT NAME: Monthly Coliforms
DATE: 02/06/2026

SAMPLE NUMBER- 968228 SAMPLE ID- 4/Quinn Estates WWTP
DATE SAMPLED- 02/04/26
DATE RECEIVED- 02/04/26 SAMPLER- Client
TIME RECEIVED- 1315 DELIVERED BY- Jack Plewak

SAMPLE MATRIX- WA
TIME SAMPLED- 0805
RECEIVED BY- EM
TYPE SAMPLE- Grab

Page 1 of 1

ANALYSIS	METHOD	ANALYSIS DATE	TIME	BY	RESULT UNITS
Sample Receipt Temperature		02/04/26		CES	1.4 Degrees C
Total Coliform	Colilert	02/04/26	1604	BLO	< 1 cfu/100ml

NYSDOH LAB ID NO. 11246

APPROVED BY:

(Terms and Conditions on Reverse Side)

Barbara L. DuChene
Laboratory Manager

Note: Reported result is negative.

The state sanitary code states that acceptable drinking water must contain no coliform bacteria. In order to be acceptable your sample must be "< 1". If your result is not "< 1" then you should call your local health department for advice on how to improve your water's quality. This sample meets NYS Standards for Total Coliform.

E-Coli Not Present

**A copy of this report was sent
to the NYS Health Dept.**



**Certified
Environmental
Services, Inc.**

7280 Caswell Street
North Syracuse, NY 13212
Phone 315-478-2374
Fax 315-478-2107

REPORT OF ANALYSES

Town Of Chenango
1529 NY Route 12
Binghamton, NY 13905-
Attn: Greg Burden

PROJECT NAME: Monthly Coliforms
DATE: 02/06/2026

SAMPLE NUMBER- 968229 SAMPLE ID- 5/CB Medical
DATE SAMPLED- 02/04/26
DATE RECEIVED- 02/04/26 SAMPLER- Client
TIME RECEIVED- 1315 DELIVERED BY- Jack Plewak

SAMPLE MATRIX- WA
TIME SAMPLED- 0820
RECEIVED BY- EM
TYPE SAMPLE- Grab

Page 1 of 1

ANALYSIS	METHOD	ANALYSIS DATE	TIME	BY	RESULT UNITS
Sample Receipt Temperature		02/04/26		CES	1.4 Degrees C
Total Coliform	Colilert	02/04/26	1604	BLO	< 1 cfu/100ml

NYSDOH LAB ID NO. 11246

APPROVED BY:

(Terms and Conditions on Reverse Side)

Barbara L. DuChene
Laboratory Manager

Note: Reported result is negative.

The state sanitary code states that acceptable drinking water must contain no coliform bacteria. In order to be acceptable your sample must be "< 1". If your result is not "< 1" then you should call your local health department for advice on how to improve your water's quality. This sample meets NYS Standards for Total Coliform.

E-Coli Not Present

**A copy of this report was sent
to the NYS Health Dept.**



**Certified
Environmental
Services, Inc.**

7280 Caswell Street
North Syracuse, NY 13212
Phone 315-478-2374
Fax 315-478-2107

REPORT OF ANALYSES

Town Of Chenango
1529 NY Route 12
Binghamton, NY 13905-
Attn: Greg Burden

PROJECT NAME: Monthly Coliforms
DATE: 02/06/2026


SAMPLE NUMBER- 968230 SAMPLE ID- 6/5 Katteville Rd. Mirabito SAMPLE MATRIX- WA
DATE SAMPLED- 02/04/26 TIME SAMPLED- 0830
DATE RECEIVED- 02/04/26 SAMPLER- Client RECEIVED BY- EM
TIME RECEIVED- 1315 DELIVERED BY- Jack Plewak TYPE SAMPLE- Grab

Page 1 of 1

ANALYSIS	METHOD	ANALYSIS DATE	TIME	BY	RESULT UNITS
Sample Receipt Temperature		02/04/26		CES	1.4 Degrees C
Total Coliform	Colilert	02/04/26	1604	BLO	< 1 cfu/100ml

NYSDOH LAB ID NO. 11246

APPROVED BY:


(Terms and Conditions on Reverse Side)

Barbara L. DuChene
Laboratory Manager

Note: Reported result is negative.

The state sanitary code states that acceptable drinking water must contain no coliform bacteria. In order to be acceptable your sample must be "< 1". If your result is not "< 1" then you should call your local health department for advice on how to improve your water's quality. This sample meets NYS Standards for Total Coliform.

E-Coli Not Present

**A copy of this report was sent
to the NYS Health Dept.**



Certified
Environmental
Services, Inc.

7280 Caswell Street
North Syracuse, NY 13212
Phone 315-478-2374
Fax 315-478-2107

REPORT OF ANALYSES

Town Of Chenango
1529 NY Route 12
Binghamton, NY 13905-
Attn: Greg Burden

PROJECT NAME: Monthly Coliforms
DATE: 02/06/2026

SAMPLE NUMBER- 968231 SAMPLE ID- 7/85 Poplar Hill Rd.
DATE SAMPLED- 02/04/26
DATE RECEIVED- 02/04/26 SAMPLER- Client
TIME RECEIVED- 1315 DELIVERED BY- Jack Plewak

SAMPLE MATRIX- WA
TIME SAMPLED- 0841
RECEIVED BY- EM
TYPE SAMPLE- Grab

Page 1 of 1

ANALYSIS	METHOD	ANALYSIS DATE	TIME	BY	RESULT UNITS
Sample Receipt Temperature		02/04/26		CES	1.4 Degrees C
Total Coliform	Colilert	02/04/26	1604	BLO	< 1 cfu/100ml

NYSDOH LAB ID NO. 11246

APPROVED BY:

(Terms and Conditions on Reverse Side)

Barbara L. DuChene
Laboratory Manager

Note: Reported result is negative.

The state sanitary code states that acceptable drinking water must contain no coliform bacteria. In order to be acceptable your sample must be "< 1". If your result is not "< 1" then you should call your local health department for advice on how to improve your water's quality. This sample meets NYS Standards for Total Coliform.

E-Coli Not Present

A copy of this report was sent
to the NYS Health Dept.



**Certified
Environmental
Services, Inc.**

7280 Caswell Street
North Syracuse, NY 13212
Phone 315-478-2374
Fax 315-478-2107

REPORT OF ANALYSES

Town Of Chenango
1529 NY Route 12
Binghamton, NY 13905-
Attn: Greg Burden

PROJECT NAME: Monthly Coliforms
DATE: 02/06/2026

SAMPLE NUMBER- 968232 SAMPLE ID- 8/1251 River Rd.
DATE SAMPLED- 02/04/26
DATE RECEIVED- 02/04/26 SAMPLER- Client
TIME RECEIVED- 1315 DELIVERED BY- Jack Plewak


SAMPLE MATRIX- WA
TIME SAMPLED- 0850
RECEIVED BY- EM
TYPE SAMPLE- Grab

Page 1 of 1

ANALYSIS	METHOD	ANALYSIS DATE	TIME	BY	RESULT UNITS
Sample Receipt Temperature		02/04/26		CES	1.4 Degrees C
Total Coliform	Colilert	02/04/26	1604	BLO	< 1 cfu/100ml

NYSDOH LAB ID NO. 11246

APPROVED BY:


(Terms and Conditions on Reverse Side)

**Barbara L. DuChene
Laboratory Manager**

Note: Reported result is negative.

The state sanitary code states that acceptable drinking water must contain no coliform bacteria. In order to be acceptable your sample must be "< 1". If your result is not "< 1" then you should call your local health department for advice on how to improve your water's quality. This sample meets NYS Standards for Total Coliform.

E-Coli Not Present

**A copy of this report was sent
to the NYS Health Dept.**



Certified
Environmental
Services, Inc.

7280 Caswell Street
North Syracuse, NY 13212
Phone 315-478-2374
Fax 315-478-2107

REPORT OF ANALYSES

Town Of Chenango
1529 NY Route 12
Binghamton, NY 13905-
Attn: Greg Burden

PROJECT NAME: Monthly Coliforms
DATE: 02/06/2026

SAMPLE NUMBER- 968233 SAMPLE ID- 9/3 Matthews
DATE SAMPLED- 02/04/26
DATE RECEIVED- 02/04/26 SAMPLER- Client
TIME RECEIVED- 1315 DELIVERED BY- Jack Plewak

SAMPLE MATRIX- WA
TIME SAMPLED- 0859
RECEIVED BY- EM
TYPE SAMPLE- Grab

Page 1 of 1

ANALYSIS	METHOD	ANALYSIS DATE	TIME	BY	RESULT UNITS
Sample Receipt Temperature		02/04/26		CES	1.4 Degrees C
Total Coliform	Colilert	02/04/26	1604	BLO	< 1 cfu/100ml

NYSDOH LAB ID NO. 11246

APPROVED BY:

(Terms and Conditions on Reverse Side)

Barbara L. DuChene
Laboratory Manager

Note: Reported result is negative.

The state sanitary code states that acceptable drinking water must contain no coliform bacteria. In order to be acceptable your sample must be "< 1". If your result is not "< 1" then you should call your local health department for advice on how to improve your water's quality. This sample meets NYS Standards for Total Coliform.

E-Coli Not Present

A copy of this report was sent
to the NYS Health Dept.



**Certified
Environmental
Services, Inc.**

7280 Caswell Street
North Syracuse, NY 13212
Phone 315-478-2374
Fax 315-478-2107

REPORT OF ANALYSES

Town Of Chenango
1529 NY Route 12
Binghamton, NY 13905-
Attn: Greg Burden

PROJECT NAME: Monthly Coliforms
DATE: 02/06/2026

SAMPLE NUMBER- 968234 SAMPLE ID- 10/73 Pamela Dr.
DATE SAMPLED- 02/04/26
DATE RECEIVED- 02/04/26 SAMPLER- Client
TIME RECEIVED- 1315 DELIVERED BY- Jack Plewak

SAMPLE MATRIX- WA
TIME SAMPLED- 0915
RECEIVED BY- EM
TYPE SAMPLE- Grab

Page 1 of 1

ANALYSIS	METHOD	ANALYSIS DATE	TIME	BY	RESULT UNITS
Sample Receipt Temperature		02/04/26		CES	1.4 Degrees C
Total Coliform	Colilert	02/04/26	1604	BLO	< 1 cfu/100ml

NYSDOH LAB ID NO. 11246

APPROVED BY:


(Terms and Conditions on Reverse Side)
Barbara L. DuChene
Laboratory Manager

Note: Reported result is negative.

The state sanitary code states that acceptable drinking water must contain no coliform bacteria. In order to be acceptable your sample must be "< 1". If your result is not "< 1" then you should call your local health department for advice on how to improve your water's quality. This sample meets NYS Standards for Total Coliform.

E-Coli Not Present

**A copy of this report was sent
to the NYS Health Dept.**

CHAIN OF CUSTODY RECORD (SEE BACK FOR TERMS & CONDITIONS)



Certified
Environmental
Services, Inc.

7280 Caswell St. (Hancock Air Park)
North Syracuse, New York 13212
Phone 315-478-2374
Fax 315-478-2107

CLIENT NAME: Town of Chenango

ADDRESS: 1529 NY Rt. 12

Binghamton, NY 13901

CONTACT NAME: Attn: Mr. Gregory Burden

CLIENT PHONE:

PROJECT #/NAME/PO #: Monthly Coliforms

FAX:

CES BATCH NO: 17590

PAGE 1

OF

Standard TAT is end of day, 10 working days after lab receipt. Samples received after 2 pm are considered next day business. Rush TAT subject to laboratory approval and surcharges.

Turn-Around Time ☐ Standard ☐ 5 Working Days ☐ 3 Working Days

☐ 2 Working Days ☐ 1 Working Days

CES LOG NUMBERS (INTERNAL USE/DO NOT WRITE)	Collected		Matrix	Grab or Comp.	CLIENT ID/SAMPLE LOCATION	Number of Containers										Remarks
	Date	Time				1	2	3	4	5	6	7	8	9	10	
968225	2/4/26	719	PW	Grab	1 Pennview WWTP	1	X									
226	2/4/26	730	PW	Grab	2 Nirchis 954 Front St.	1	X									
227	2/4/26	751	PW	Grab	3 1290 Front St.	1	X									
228	2/4/26	805	PW	Grab	4 Quinn Estates WWTP	1	X									
229	2/4/26	820	PW	Grab	5 CB Medical	1	X									
230	2/4/26	830	PW	Grab	6 5 Katteville Rd. Mirabito	1	X									
231	2/4/26	841	PW	Grab	7 85 Poplar Hill Rd.	1	X									
232	2/4/26	850	PW	Grab	8 1251 River Rd	1	X									
233	2/4/26	859	PW	Grab	9 3 Matthews	1	X									
234	2/4/26	915	PW	Grab	10 73 Pamela Dr.	1	X									

Preservative Codes: A= Unpreserved B=H₂SO₄ C=HCl D=NaOH E=Ascorbic Acid F=HNO₃
G=Na₂S₂O₃ H= I=

Parameter and Method: 1 T-Coliform

Sample bottle: Type Sterile Size 140 ml

Preservative Code: G

Samples Collected By: Gregory Burden

Name (Print): Gregory Burden

Signature: [Signature]

Company: TCC

Remarks:

RELINQUISHED BY:	Date	Time	RECEIVED BY:
Name: Gregory Burden	2/4/26	130	Name: Sack Prewash
Signature: [Signature]		940	Signature: [Signature]
Name: Sack Prewash	2-4-26	1315	Name: Emily McManus
Signature: [Signature]			Signature: [Signature]

Samples Received in Good Condition: ☐ Yes ☐ No

Receipt Temperature: 1.4 °C



**Certified
Environmental
Services, Inc.**

7280 Caswell Street
North Syracuse, NY 13212
Phone 315-478-2374
Fax 315-478-2107

Sample Receiving Checklist

Client Name: TIO Chenango

Batch Number: M7596

- | | Yes | No | If No Explain: |
|---|-------------------------------------|--------------------------|----------------|
| 1. Proper Full and Complete Documentation: | ☒ | ☐ | |
| 2. Appropriate Sample Containers: | ☒ | ☐ | |
| 3. Adequate Sample Volume: | ☒ | ☐ | |
| 4. Hold Time(OK): | ☒ | ☐ | |
| 5. Proper Sample Labeling: | ☒ | ☐ | |
| 6. Sample Temperature: | ☒ | ☐ | |
| 7. Sample Received on Ice: (Not required for Bact) | ☒ | ☐ | |
| 8. Preservation OK: (Microbiology See Below) | ☐ | ☐ | |
| 9. Preservation Not Applicable:(ie: Solid/Sludge, Alk,BOD,TSS,TS,Cl,Fl,SO4,pH,Cond, etc): | ☒ | | |
| 10. CES Sample Container(s): If not sure ask client | ☒ | ☐ | |

(If preservation required note Lot # associated with preservative if available.)

H₂SO₄ WC HNO₃ MT NaOH WCSP Ascorbic Acid WC

HCl WCSP Na₂S₂O₃ WC Other _____ Not Available ☐

Microbiology: ☒ Chlorinated Source (Sodium Thiosulfate)
☐ Non-Chlorinated Source (No Sodium Thiosulfate)

Additional Comments/Client Correspondence _____

Sample(s) Received By: EM Sample(s) Logged In By: TS Login Reviewed By: BLD

DOCUMENT ID: SRCL072522

Approved by: RRB

Date Put In Place: 11/28/23

CERTIFIED ENVIRONMENTAL SERVICES, INC.

TERMS AND CONDITIONS

1. Services completed by Certified Environmental Services, Inc. are done so in general accordance with the environmental services and/or analytical industries recognized methods.
2. Certified Environmental Services, Inc. does not assume any other liabilities other than re-performance of the work if the completed services are determined to be deficient due to the negligence of Certified Environmental Services, Inc. Under no circumstances shall Certified Environmental Services, Inc., its employees, agents or sub-contractors be responsible for consequential or special damages of any kind or in any amount.
3. Any claim made must be done in writing within thirty (30) days of Certified Environmental Services, Inc.'s written report.
4. Certified Environmental Services, Inc. will not accept any liability in whole or in part as a result of data interpretation by the client.
5. All reports are submitted in writing to our customers only. Certified Environmental Services, Inc. will not be responsible for the accuracy of the contents of any report obtained by anyone other than our Client.
6. Invoices for services rendered are generated periodically as the work is completed. All invoices are due within thirty (30) days of the invoice date. Any discrepancy with an invoice must be reported to the accounts receivable department within fifteen (15) days of the invoice date. All balances over thirty (30) days will be subject to a 1-1/2% finance charge.
7. The terms and conditions set forth herein shall not be altered in any way unless done so in writing and signed by a Manager of Certified Environmental Services, Inc.

Qualifiers (Updated 09.12.2018):

ND-Not Detected at reporting limit	NR-Not Reported	NA-Not Available
H-Regulatory hold time exceeded	R-Duplication outside in-house acceptance limits	
B-Analyte detected in Method Blank	A-Preservation incomplete. Additional acid added to sample prior to analysis.	
DO-Spike Diluted Out	E-Estimate	MDL-Method Detection Limit
S-Spike recovery outside acceptance limits (+ is over – is under, results may be biased high or biased low)		
L-Laboratory Control Sample outside acceptance limits (+ is over – is under, results may be biased high or biased low)		

#- NYS ELAP does not offer accreditation for this parameter.

**For Solid Waste analysis where there is no approved method, this is a laboratory developed method.

F - Filtration not performed within 15 minutes of sample collection as required by cited method.

E - Total Suspended Solids, Estimate. Residue on filter below method requirement of 2.5 mg.

E - Biochemical Oxygen Demand, Estimate. Depletion less than 2.0 as required by cited method.

X- Exceeds maximum contamination limit.