



**Certified
Environmental
Services, Inc.**

7280 Caswell Street
North Syracuse, NY 13212
Phone 315-478-2374
Fax 315-478-2107

REPORT OF ANALYSES

Town Of Chenango
1529 NY Route 12
Binghamton, NY 13905-
Attn: Greg Burden

PROJECT NAME: Lead/Copper
DATE: 03/20/2026

SAMPLE NUMBER- 970320 SAMPLE ID- EP 104(12A Well)
DATE SAMPLED- 03/04/26
DATE RECEIVED- 03/04/26 SAMPLER- Client
TIME RECEIVED- 1325 DELIVERED BY- Jack Plewak

SAMPLE MATRIX- WA
TIME SAMPLED- 0742
RECEIVED BY- EM
TYPE SAMPLE- Grab


Page 1 of 1

ANALYSIS	METHOD	SAMPLE PREP		ANALYSIS		TIME	BY	RESULT	UNITS
		DATE	BY	DATE	BY				
Copper, Total	EPA 200.7	03/06/26	MG	03/19/26	MG			< 0.02	mg/L
Lead, Total (Pb)	EPA 200.8	03/10/26	PAC	03/10/26	PAC			< 0.001	mg/L

Note: Lead analysis performed by ELAP #10478.

NYSDOH LAB ID NO. 11246

APPROVED BY:


(Terms and Conditions on Reverse Side)

**Barbara L. DuChene
Laboratory Manager**

CHAIN OF CUSTODY RECORD (SEE BACK FOR TERMS & CONDITIONS)



Certified
Environmental
Services, Inc.

7280 Caswell St. (Hancock Air Park)
North Syracuse, New York 13212
Phone 315-478-2374
Fax 315-478-2107

CES BATCH NO: M 815Z OF 1 PAGE

Standard TAT is end of day, 10 working days after lab receipt. Samples received after 2 pm are considered next day business. Rush TAT subject to laboratory approval and surcharges.
Turn-Around Time 3 Working Days
 Standard 5 Working Days
 2 Working Days 1 Working Days

CLIENT NAME: Town of Chenango
ADDRESS: 1529 NY Rt. 12
Binghamton, NY 13901
CONTACT NAME: Attn: Mr. Gregory Burden
CLIENT PHONE: _____ FAX: _____
PROJECT #/NAME/PO #: Lead/Copper

CES LOG NUMBERS <small>(INTERNAL USE DO NOT WRITE)</small>	Collected		Matrix	Grab or Comp.	CLIENT ID/SAMPLE LOCATION	Number of Containers										Remarks				
	Date	Time				1	2	3	4	5	6	7	8	9	10					
<u>AS 15 970320</u>	<u>3/4/26</u>	<u>742</u>	<u>PW</u>	<u>Grab</u>	<u>EP 104 (12A well)</u>															
<u>BS 3.4-26</u>																				

Preservative Codes: A= Unpreserved B=H₂SO₄ C=HCl D=NaOH E=Ascorbic Acid F=HNO₃
G=Na₂S₂O₃ H= _____ I= _____

Parameter and Method: PB, CU

Sample bottle: Type plastic Size 2L

Preservative Code: A

Samples Collected By: Name (Print): Gregory Burden
Signature: _____
Company: TAC

RELINQUISHED BY: Name: Gregory Burden Date: 3/4/26 Time: 920
Signature: _____
Name: Jack Newk Date: 3-4-26 Time: 1325
Signature: [Signature]

RECEIVED BY: Name: Jack Newk
Signature: [Signature]
Name: Emily McMans
Signature: [Signature]

Receipt Temperature: 1.4 °C

Yes No



**Certified
Environmental
Services, Inc.**

7280 Caswell Street
North Syracuse, NY 13212
Phone 315-478-2374
Fax 315-478-2107

Sample Receiving Checklist

Client Name: TIG Chenango

Batch Number: <u>M8152</u>	Yes	No	If No Explain:
1. Proper Full and Complete Documentation:	<input checked="" type="checkbox"/>	<input type="checkbox"/>	_____
2. Appropriate Sample Containers:	<input checked="" type="checkbox"/>	<input type="checkbox"/>	_____
3. Adequate Sample Volume:	<input checked="" type="checkbox"/>	<input type="checkbox"/>	_____
4. Hold Time(OK):	<input checked="" type="checkbox"/>	<input type="checkbox"/>	_____
5. Proper Sample Labeling:	<input checked="" type="checkbox"/>	<input type="checkbox"/>	_____
6. Sample Temperature:	<input checked="" type="checkbox"/>	<input type="checkbox"/>	_____
7. Sample Received on Ice: (Not required for Bact)	<input checked="" type="checkbox"/>	<input type="checkbox"/>	_____
8. Preservation OK: (Microbiology See Below)	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<u>preserved w/ 1ml HNO₃ to pH < 2 at lab</u>
9. Preservation Not Applicable:(ie: Solid/Sludge, Alk,BOD,TSS,TS,Cl,F1,SO4,pH,Cond, etc):	<input type="checkbox"/>	<input type="checkbox"/>	_____
10. CES Sample Container(s): If not sure ask client	<input checked="" type="checkbox"/>	<input type="checkbox"/>	_____

(If preservation required note Lot # associated with preservative if available.)

H₂SO₄ WC HNO₃ MT NaOH WCSP Ascorbic Acid WC
 HCl WCSP Na₂S₂O₃ WC Other _____ Not Available

Microbiology: Chlorinated Source (Sodium Thiosulfate)
 Non-Chlorinated Source (No Sodium Thiosulfate)

Additional Comments/Client Correspondence _____

Sample(s) Received By: Em Sample(s) Logged In By: RS Login Reviewed By: BCD

CERTIFIED ENVIRONMENTAL SERVICES, INC.

TERMS AND CONDITIONS

1. Services completed by Certified Environmental Services, Inc. are done so in general accordance with the environmental services and/or analytical industries recognized methods.
2. Certified Environmental Services, Inc. does not assume any other liabilities other than re-performance of the work if the completed services are determined to be deficient due to the negligence of Certified Environmental Services, Inc. Under no circumstances shall Certified Environmental Services, Inc., its employees, agents or sub-contractors be responsible for consequential or special damages of any kind or in any amount.
3. Any claim made must be done in writing within thirty (30) days of Certified Environmental Services, Inc.'s written report.
4. Certified Environmental Services, Inc. will not accept any liability in whole or in part as a result of data interpretation by the client.
5. All reports are submitted in writing to our customers only. Certified Environmental Services, Inc. will not be responsible for the accuracy of the contents of any report obtained by anyone other than our Client.
6. Invoices for services rendered are generated periodically as the work is completed. All invoices are due within thirty (30) days of the invoice date. Any discrepancy with an invoice must be reported to the accounts receivable department within fifteen (15) days of the invoice date. All balances over thirty (30) days will be subject to a 1-1/2% finance charge.
7. The terms and conditions set forth herein shall not be altered in any way unless done so in writing and signed by a Manager of Certified Environmental Services, Inc.

Qualifiers (Updated 09.12.2018):

ND-Not Detected at reporting limit

NR-Not Reported

NA-Not Available

H-Regulatory hold time exceeded

R-Duplication outside in-house acceptance limits

B-Analyte detected in Method Blank

A-Preservation incomplete. Additional acid added to sample prior to analysis.

DO-Spike Diluted Out

E-Estimate

MDL-Method Detection Limit

S-Spike recovery outside acceptance limits (+ is over – is under, results may be biased high or biased low)

L-Laboratory Control Sample outside acceptance limits (+ is over – is under, results may be biased high or biased low)

#- NYS ELAP does not offer accreditation for this parameter.

**For Solid Waste analysis where there is no approved method, this is a laboratory developed method.

F - Filtration not performed within 15 minutes of sample collection as required by cited method.

E - Total Suspended Solids, Estimate. Residue on filter below method requirement of 2.5 mg.

E - Biochemical Oxygen Demand, Estimate. Depletion less than 2.0 as required by cited method.

X- Exceeds maximum contamination limit.