CES Certified Environmental Services, Inc.

7280 Caswell Street
North Syracuse, NY 13212
Phone 315-478-2374
Fax 315-478-2107

REPORT OF ANALYSES

Town Of Chenango
1529 NY Route 12
Binghamton, NY 13905-
Attn: Greg Burden

PROJECT NAME: Nitrate
DATE: 04/10/2025

SAMPLE NUMBER- 942450 SAMPLE ID- EP 104
DATE SAMPLED- 04/09/25
DATE RECEIVED- 04/09/25 SAMPLER- Client
TIME RECEIVED- 1250 DELIVERED BY- Pat Davis(CES)

SAMPLE MATRIX- WA
TIME SAMPLED- 0715
RECEIVED BY- EM
TYPE SAMPLE- Grab

Page 1 of 1

ANALYSIS	METHOD	ANALYSIS DATE	TIME	BY	RESULT	UNITS
Sample Receipt Temperature		04/09/25		CES	3.8	Degrees C
Nitrate as N	Hach 10206	04/10/25	1432	AM	1.07	mg/L

NYSDOH LAB ID NO. 11246

APPROVED BY: _____
(Terms and Conditions on Reverse Side)

Barbara L. DuChene
Laboratory Manager

Nitrate - Maximum Contaminant Level = 10.mg/L(ppm)
Nitrite - Maximum Contaminant Level = 1.0 mg/L(ppm)
Total Nitrate and Nitrite - Maximum Contaminant Level = 10.mg/L(ppm)

The analytical results on this sample are representative of the sample received by the Laboratory.

CES Certified Environmental Services, Inc.

7280 Caswell Street
North Syracuse, NY 13212
Phone 315-478-2374
Fax 315-478-2107

REPORT OF ANALYSES

Town Of Chenango
1529 NY Route 12
Binghamton, NY 13905-
Attn: Greg Burden

PROJECT NAME: Nitrate
DATE: 04/10/2025

SAMPLE NUMBER- 942451 SAMPLE ID- EP 106
DATE SAMPLED- 04/09/25
DATE RECEIVED- 04/09/25 SAMPLER- Client
TIME RECEIVED- 1250 DELIVERED BY- Pat Davis(CES)

SAMPLE MATRIX- WA
TIME SAMPLED- 0730
RECEIVED BY- EM
TYPE SAMPLE- Grab

Page 1 of 1

ANALYSIS	METHOD	ANALYSIS DATE	TIME	BY	RESULT	UNITS
Sample Receipt Temperature		04/09/25		CES	3.8	Degrees C
Nitrate as N	Hach 10206	04/10/25	1432	AM	0.62	mg/L

NYSDOH LAB ID NO. 11246

APPROVED BY: _____
(Terms and Conditions on Reverse Side)
Barbara L. DuChene
Laboratory Manager

Nitrate - Maximum Contaminant Level = 10.mg/L(ppm)
Nitrite - Maximum Contaminant Level = 1.0 mg/L(ppm)
Total Nitrate and Nitrite - Maximum Contaminant Level = 10.mg/L(ppm)

The analytical results on this sample are representative of the sample received by the Laboratory.

CES Certified Environmental Services, Inc.

7280 Caswell Street
North Syracuse, NY 13212
Phone 315-478-2374
Fax 315-478-2107

REPORT OF ANALYSES

Town Of Chenango
1529 NY Route 12
Binghamton, NY 13905-
Attn: Greg Burden

PROJECT NAME: Nitrate
DATE: 04/10/2025

SAMPLE NUMBER- 942452 SAMPLE ID- EP 110
DATE SAMPLED- 04/09/25
DATE RECEIVED- 04/09/25 SAMPLER- Client
TIME RECEIVED- 1250 DELIVERED BY- Pat Davis(CES)

SAMPLE MATRIX- WA
TIME SAMPLED- 0745
RECEIVED BY- EM
TYPE SAMPLE- Grab

Page 1 of 1

ANALYSIS	METHOD	ANALYSIS DATE	TIME	BY	RESULT	UNITS
Sample Receipt Temperature		04/09/25		CES	3.8	Degrees C
Nitrate as N	Hach 10206	04/10/25	1432	AM	6.05	mg/L

NYSDOH LAB ID NO. 11246

APPROVED BY: _____
(Terms and Conditions on Reverse Side)

Barbara L. DuChene
Laboratory Manager

Nitrate - Maximum Contaminant Level = 10.mg/L(ppm)
Nitrite - Maximum Contaminant Level = 1.0 mg/L(ppm)
Total Nitrate and Nitrite - Maximum Contaminant Level = 10.mg/L(ppm)

The analytical results on this sample are representative of the sample received by the Laboratory.

CES Certified Environmental Services, Inc.

7280 Caswell Street
North Syracuse, NY 13212
Phone 315-478-2374
Fax 315-478-2107

REPORT OF ANALYSES

Town Of Chenango
1529 NY Route 12
Binghamton, NY 13905-
Attn: Greg Burden

PROJECT NAME: Nitrate
DATE: 04/10/2025

SAMPLE NUMBER- 942453 SAMPLE ID- EP 108
DATE SAMPLED- 04/09/25
DATE RECEIVED- 04/09/25 SAMPLER- Client
TIME RECEIVED- 1250 DELIVERED BY- Pat Davis(CES)

SAMPLE MATRIX- WA
TIME SAMPLED- 0800
RECEIVED BY- EM
TYPE SAMPLE- Grab

Page 1 of 1

ANALYSIS	METHOD	ANALYSIS DATE	TIME	BY	RESULT	UNITS
Sample Receipt Temperature		04/09/25		CES	3.8	Degrees C
Nitrate as N	Hach 10206	04/10/25	1432	AM	1.28	mg/L

NYSDOH LAB ID NO. 11246

APPROVED BY: _____
(Terms and Conditions on Reverse Side)

Barbara L. DuChene
Laboratory Manager

Nitrate - Maximum Contaminant Level = 10.mg/L(ppm)
Nitrite - Maximum Contaminant Level = 1.0 mg/L(ppm)
Total Nitrate and Nitrite - Maximum Contaminant Level = 10.mg/L(ppm)

The analytical results on this sample are representative of the sample received by the Laboratory.

CES Certified Environmental Services, Inc.

7280 Caswell Street
North Syracuse, NY 13212
Phone 315-478-2374
Fax 315-478-2107

REPORT OF ANALYSES

Town Of Chenango
1529 NY Route 12
Binghamton, NY 13905-
Attn: Greg Burden

PROJECT NAME: Nitrate
DATE: 04/10/2025

SAMPLE NUMBER- 942454 SAMPLE ID- EP 111
DATE SAMPLED- 04/09/25
DATE RECEIVED- 04/09/25 SAMPLER- Client
TIME RECEIVED- 1250 DELIVERED BY- Pat Davis(CES)

SAMPLE MATRIX- WA
TIME SAMPLED- 0830
RECEIVED BY- EM
TYPE SAMPLE- Grab

Page 1 of 1

ANALYSIS	METHOD	ANALYSIS DATE	TIME	BY	RESULT	UNITS
Sample Receipt Temperature		04/09/25		CES	3.8	Degrees C
Nitrate as N	Hach 10206	04/10/25	1432	AM	< 0.20	mg/L

NYSDOH LAB ID NO. 11246 APPROVED BY:

(Terms and Conditions on Reverse Side)

Barbara L. DuChene
Laboratory Manager

Nitrate - Maximum Contaminant Level = 10.mg/L(ppm)
Nitrite - Maximum Contaminant Level = 1.0 mg/L(ppm)
Total Nitrate and Nitrite - Maximum Contaminant Level = 10.mg/L(ppm)

The analytical results on this sample are representative of the sample received by the Laboratory.

CES Certified Environmental Services, Inc.

7280 Caswell Street
North Syracuse, NY 13212
Phone 315-478-2374
Fax 315-478-2107

REPORT OF ANALYSES

Town Of Chenango
1529 NY Route 12
Binghamton, NY 13905-
Attn: Greg Burden

PROJECT NAME: Nitrate
DATE: 04/10/2025

SAMPLE NUMBER- 942455 SAMPLE ID- EP 107
DATE SAMPLED- 04/09/25
DATE RECEIVED- 04/09/25 SAMPLER- Client
TIME RECEIVED- 1250 DELIVERED BY- Pat Davis(CES)

SAMPLE MATRIX- WA
TIME SAMPLED- 0815
RECEIVED BY- EM
TYPE SAMPLE- Grab

Page 1 of 1

ANALYSIS	METHOD	ANALYSIS DATE	TIME	BY	RESULT	UNITS
Sample Receipt Temperature		04/09/25		CES	3.8	Degrees C
Nitrate as N	Hach 10206	04/10/25	1432	AM	< 0.20	mg/L

NYSDOH LAB ID NO. 11246

APPROVED BY: _____
(Terms and Conditions on Reverse Side)

Barbara L. DuChene
Laboratory Manager

Nitrate - Maximum Contaminant Level = 10.mg/L(ppm)
Nitrite - Maximum Contaminant Level = 1.0 mg/L(ppm)
Total Nitrate and Nitrite - Maximum Contaminant Level = 10.mg/L(ppm)

The analytical results on this sample are representative of the sample received by the Laboratory.

CHAIN OF CUSTODY RECORD (SEE BACK FOR TERMS & CONDITIONS)

CES Certified Environmental Services, Inc.
7280 Caswell St. (Hancock Air Park)
North Syracuse, New York 13212
Phone 315-478-2374
Fax 315-478-2107

CES BATCH NO: L9544 PAGE ___ OF ___

Turn-Around Time Standard TAT is end of day, 10 working days after lab receipt. Samples received after 2 pm are considered next day business. Rush TAT subject to laboratory approval and surcharges.

☐ Standard ☐ 5 Working Days ☐ 3 Working Days
☐ 2 Working Days ☐ 1 Working Days

CLIENT NAME: Town of Chenango
ADDRESS: 1529 NY Rt. 12
Binghamton, NY 13901
CONTACT NAME: Attn: Mr. Gregory Burden
CLIENT PHONE: FAX:
PROJECT #/NAME/PO #: Nitrate

CES LOG NUMBERS (INTERNAL USE/DO NOT WRITE)	Collected Date	Collected Time	Matrix	Grab or Comp.	CLIENT ID/SAMPLE LOCATION	Number of Containers	1	2	3	4	5	6	7	8	9	10	Remarks
942450		715	PW	Grab	EP 104	1	X										
451		730	PW	Grab	EP 106	1	X										
452		745	PW	Grab	EP 110	1	X										
453		800	PW	Grab	EP 108	1	X										
454		830	PW	Grab	EP 111	1	X										
455		815	PW	Grab	EP 107	1	X										

	Parameter and Method:	Sample bottle: Type	Sample bottle: Size	Preservative Code:
1	Nitrate	Plastic	250 ml	A
2				
3				
4				
5				
6				
7				
8				
9				
10				

Preservative Codes: A= Unpreserved $B=H_2SO_4$ C=HCl D=NaOH E=Ascorbic Acid $F=HNO_3$
$G=Na_2S_2O_3$ H=_____ I=_____

Samples Collected By:
Name (Print): Luke Mooney
Signature: Luke Mooney
Company: Town of Chenango

Remarks:

RELINQUISHED BY:	Date	Time	RECEIVED BY:
Name: Luke Mooney Signature: Luke Mooney	4/9/25	1070 PM	Name: PAT DAVIS Signature: Pat D
Name: PAT DAVIS Signature: Pat D	4/9/25	12:50	Name: Emily McManus Signature: E

Samples Received in Good Condition: ☐ Yes ☐ No
Receipt Temperature: 3.8 °C

CES Certified Environmental Services, Inc.

7280 Caswell Street
North Syracuse, NY 13212
Phone 315-478-2374
Fax 315-478-2107

Sample Receiving Checklist

Client Name: TIO Chenango

Batch Number: L9544

	Yes	No	If No Explain:
1. Proper Full and Complete Documentation:	☑	☐	
2. Appropriate Sample Containers:	☑	☐	
3. Adequate Sample Volume:	☑	☐	
4. Hold Time(OK):	☑	☐	
5. Proper Sample Labeling:	☑	☐	
6. Sample Temperature:	☑	☐	
7. Sample Received on Ice: (Not required for Bact)	☑	☐	
8. Preservation OK: **(Microbiology See Below)**	☐	☐	
9. Preservation Not Applicable:(ie: Solid/Sludge, Alk,BOD,TSS,TS,Cl,Fl,SO4,pH,Cond, etc):	☑		
10. CES Sample Container(s): If not sure ask client	☑	☐	

(If preservation required note Lot # associated with preservative if available.)

H_2SO_4 **WC** HNO3 **MT** NaOH **WCSP** Ascorbic Acid **WC**

HCl **WCSP** $Na_2S_2O_3$ **WC** Other _____ Not Available ☐

Microbiology: ☐ Chlorinated Source (Sodium Thiosulfate)

☐ Non-Chlorinated Source (No Sodium Thiosulfate)

Additional Comments/Client Correspondence _____

Sample(s) Received By: EM Sample(s) Logged In By: RQ Login Reviewed By: DLO

DOCUMENT ID: SRCL072522 **Approved by: RRB** **Date Put In Place: 11/28/23**

CERTIFIED ENVIRONMENTAL SERVICES, INC.

TERMS AND CONDITIONS

1. **Services completed by Certified Environmental Services, Inc. are done so in general accordance with the environmental services and/or analytical industries recognized methods.**

2. **Certified Environmental Services, Inc. does not assume any other liabilities other than re-performance of the work if the completed services are determined to be deficient due to the negligence of Certified Environmental Services, Inc. Under no circumstances shall Certified Environmental Services, Inc., its employees, agents or sub-contractors be responsible for consequential or special damages of any kind or in any amount.**

3. **Any claim made must be done in writing within thirty (30) days of Certified Environmental Services, Inc.'s written report.**

4. **Certified Environmental Services, Inc. will not accept any liability in whole or in part as a result of data interpretation by the client.**

5. **All reports are submitted in writing to our customers only. Certified Environmental Services, Inc. will not be responsible for the accuracy of the contents of any report obtained by anyone other than our Client.**

6. **Invoices for services rendered are generated periodically as the work is completed. All invoices are due within thirty (30) days of the invoice date. Any discrepancy with an invoice must be reported to the accounts receivable department within fifteen (15) days of the invoice date. All balances over thirty (30) days will be subject to a 1-1/2% finance charge.**

7. **The terms and conditions set forth herein shall not be altered in any way unless done so in writing and signed by a Manager of Certified Environmental Services, Inc.**

Qualifiers (Updated 09.12.2018):

ND-Not Detected at reporting limit

NR-Not Reported

NA-Not Available

H-Regulatory hold time exceeded

R-Duplication outside in-house acceptance limits

B-Analyte detected in Method Blank

A-Preservation incomplete. Additional acid added to sample prior to analysis.

DO-Spike Diluted Out

E-Estimate

MDL-Method Detection Limit

S-Spike recovery outside acceptance limits (+ is over – is under, results may be biased high or biased low)

L-Laboratory Control Sample outside acceptance limits (+ is over – is under, results may be biased high or biased low)

#- NYS ELAP does not offer accreditation for this parameter.

**For Solid Waste analysis where there is no approved method, this is a laboratory developed method.

F - Filtration not performed within 15 minutes of sample collection as required by cited method.

E - Total Suspended Solids, Estimate. Residue on filter below method requirement of 2.5 mg.

E - Biochemical Oxygen Demand, Estimate. Depletion less than 2.0 as required by cited method.

X- Exceeds maximum contamination limit.